



**Notes**

**Floodlighting Equipment**  
 8 x 15m Masts (M1-M8)  
 Each carrying the following Floodlights :-  
 M1, M4, M5 & M8.....  
 2 x WB03/2KW/A3MAXI  
 M2, M3, M6 & M7.....  
 3 x WB03/2KW/A3MAXI

**Lamps (OSRAM)**  
 2000W/HQI-TS/W/N/L  
 (230 000 INITIAL Lm)

**Illuminance Levels**  
**Initial -**  
 (100hrs) E.i.ave = 508Lux  
**Maintained -**  
 (4000hrs) E.i.ave = 406Lux

**Uniformity**  
 Emin/Eave = 0.70

Grid values in Lux(initial).  
 Grid interval = 5m.  
 Contour values in Lux (initial).  
 Contours: 1, 5, 15, 25, 50 Lux.

**Maintenance Factor = 0.80**



Project  
 Crosfields School

[www.halliday-lighting.co.uk](http://www.halliday-lighting.co.uk)

Drawing Title  
 Proposed floodlighting

Drawn By (print)	Date
JS	19/04/2017

Project No	Scale
02780	1:750 @ A3

Drawing No	Status
HLS02780	Proposal

This page is intentionally left blank